

## Fire Marshall Codes

### For Indoor Events in Assembly Occupancies

#### Occupancy Load

- ▶ Maximum occupancy loads will not be exceeded under any circumstances.

#### Egress Issues

- ▶ At any time will any exit door be made inaccessible.
- ▶ Exit corridors will not be used for displays or be otherwise obstructed.
- ▶ Booths and/or displays shall be arranged to maintain free, immediate and unobstructed access to exits and exit corridors.
- ▶ Trade show events or any event with booth space will be made available to the
- ▶ Fire Dept. a map of a booth location and occupants.
- ▶ All trade show booth configurations shall be subject to change if the Fire Dept. feels egress issues warrant such a change.

#### Motor Vehicles - Fueled vehicles shall comply with the following:

- ▶ Batteries disconnected.
- ▶ Fuel not to exceed ¼ tank or 5 gals whichever is less
- ▶ Fuel tank fill is secure.
- ▶ No fueling or defueling inside building

#### Vegetation

- ▶ Displays with highly combustible materials in exit access aisles, corridors, or within 5 ft. of exits is not permitted.

#### Electrical

- ▶ All electrical connections shall comply with the current electrical fire code.
- ▶ Multiplug adapters and unfused multi strips shall not be used.
- ▶ Extension cords shall not be affixed to structures, extend through walls, ceilings, floors, under doors, or floor coverings. They shall be plugged directly into an approved receptacle or fused multi-plug adapter and shall serve one appliance. All cords shall be listed for specific use.

#### Cooking

- ▶ No deep fat frying without an approved, listed exhaust and suppression system in place.
- ▶ All cooking done indoors will need prior approval from the Fire Dept.
- ▶ Any area where cooking will take place shall have appropriate and listed fire
- ▶ Extinguishers located at the site.

## Flammable Liquids

- ▶ Any vendor or booth with flammable liquids will need prior approval from Fire Dept.

## Explosives [small arms ammunition]

- ▶ Smokeless propellants shall be stored in approved containers conforming with DOTn 49 CFR, Part 173.
- ▶ No repackaging of smokeless propellants, black powder, or small arms primers shall be done on premises.
- ▶ No more than 20- lb. containers of smokeless propellants will be displayed
- ▶ No more than 1 lb. of black powder shall be displayed.
- ▶ No more than 10,000 small arms primers shall be displayed.
- ▶ Quantities exceeding those amounts shall comply with the 2003 IF Sections 3306.5.2.1 through 3306.5.2.3.

## Indoor Pyrotechnics

- ▶ Any event using Proximity Indoor Pyrotechnics must comply with all S.C. State Fire Marshall's Office & Florence Fire Dept. regulations.

## Fire Dept. on Site

- ▶ Anytime the fire department is required to be on site for an event, current rates will apply.